

The Water We Drink

Monroe Water System

Public Water Supply ID: LA1073031

We are pleased to present to you the Annual Water Quality Report for the year 2010. This report is designed to inform you about the quality of your water and services we deliver to you every day (Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien). Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

Here is text to display for the SWAP Systems

Our water source(s) are listed below:

Source Name	Source Water Type	Source Water Body Name
Bayou Desiard Surface Water Intake	Surface Water	Bayou Desiard
Ouachita River Surface Water Intake	Surface Water	Ouachita River

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

Microbial Contaminants - such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic Contaminants - such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and Herbicides - which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

Organic Chemical Contaminants – including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

Radioactive Contaminants – which can be naturally-occurring or be the result of oil and gas production and mining activities.

A Source Water Assessment Plan (SWAP) is now available from our office. This plan is an assessment of a delineated area around our listed sources through which contaminants, if present, could migrate and reach our source water. It also includes an inventory of potential sources of contamination within the delineated area, and a determination of the water supply's susceptibility to contamination by the identified potential sources. According to the Source Water Assessment Plan, our water system had a susceptibility rating of 'HIGH'. If you would like to review the Source Water Assessment Plan, please feel free to contact our office at the number provided in the following paragraph.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Monroe Water System is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for public health. We are pleased to report that our drinking water is safe and meets Federal and State requirements. We want our valued customers to be informed about their water utility. If you have any questions about this report, want to attend any scheduled meetings, or simply want to learn more about your drinking water, please contact James E. Mayo at 318-329-2310.

The Louisiana Department of Health and Hospitals - Office of Public Health routinely monitors for constituents in your drinking water according to Federal and State laws. The tables that follow show the results of our monitoring during the period of January 1st to December 31st, 2010. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk.

In the tables below, you will find many terms and abbreviations you might not be familiar with.

To help you better understand these terms, we've provided the following definitions:

Parts per million (ppm) or Milligrams per liter (mg/L) – one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter (ug/L) – one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries per liter (pCi/L) – picocuries per liter is a measure of the radioactivity in water.

Nephelometric Turbidity Unit (NTU) – nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Action level (AL) – the concentration of a contaminant that, if exceeded, triggers treatment or other requirements that a water system must follow.

Treatment technique (TT) – a treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum contaminant level (MCL) – the “Maximum Allowed” MCL is the highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLG's as feasible using the best available treatment technology.

Maximum contaminant level goal (MCLG) – the “Goal” is the level of a contaminant in drinking water below which there is no known or expected risk to human health. MCLG's allow for a margin of safety.

Maximum residual disinfectant level (MRDL) – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum residual disinfectant level goal (MRDLG) – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

During the period covered by this report we had below noted violations of drinking water regulations.

Type	Category	Analyte	Compliance Period
MONITORING, ROUTINE (DBP), MAJOR	Failure to Monitor	CARBON, TOTAL	05/01/2010 - 05/31/2010
INADEQUATE DBP PRECURSOR REMOVAL	Treatment Technique Violation	CARBON, TOTAL	04/01/2010 - 06/30/2010
INADEQUATE DBP PRECURSOR REMOVAL	Treatment Technique Violation	CARBON, TOTAL	07/01/2010 - 09/30/2010
INADEQUATE DBP PRECURSOR	Treatment Technique Violation	CARBON, TOTAL	10/01/2010 - 12/31/2010

REMOVAL			
FOLLOW-UP OR ROUTINE TAP M/R (LCR)	Failure to Monitor	LEAD & COPPER RULE	01/01/2008 - 12/31/2010

Our water system tested a minimum of 60 samples per month monthly sample(s) in accordance with the Total Coliform Rule for microbiological contaminants. During the monitoring period covered by this report, we had the following noted detections for microbiological contaminants:

Microbiological	Result	MCL	MCLG	Typical Source
COLIFORM (TCR)	In the month of May, 1.61% of samples returned as positive	MCL: Systems that Collect 40 or More Samples per Month - No more than 5% positive monthly samples;	0	Naturally present in the environment

In the tables below, we have shown the regulated contaminants that have detectable levels. These samples, except for Lead and Copper results and surface water systems, were collected at the raw water source and represent water before any treatment, blending or distribution. As such, the consumer tap levels could be less. Chemical Sampling of our drinking water may not be required on an annual basis; therefore, information provided in this table refers back to the latest year of chemical sampling results.

Regulated Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
ARSENIC	5/24/2010	1	1	ppb	10		Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
ATRAZINE	12/28/2010	0.4	0.4	ppb	3	3	Runoff from herbicide used on row crops
CARBON TETRACHLORIDE	5/24/2010	0.87	0.87	ppb	5	0	Discharge from chemical plants and other industrial activities
DI(2-ETHYLHEXYL) PHTHALATE	5/24/2010	0.78	0.78	ppb	6	0	Discharge from rubber and chemical factories

Lead and Copper	Date	90 TH Percentile	95 TH Percentile		Unit	AL	Sites Over AL	Typical Source
-----------------	------	-----------------------------	-----------------------------	--	------	----	---------------	----------------

LEAD	2005 - 2007	3	3		ppb	15	0	Corrosion of household plumbing systems; Erosion of natural deposits
------	-------------	---	---	--	-----	----	---	----------------------------------------------------------------------

Radionuclides	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
No Detected Results were Found in the Calendar Year of 2010							

DBP Contaminants	Monitoring Period	RAA	Range	Unit	MCL	MCLG	Typical Source
TOTAL HALOACETIC ACIDS (HAA5)	7/1/2009 - 6/30/2010	41.22155	25.19 - 72.6	ppb	60	0	By-product of drinking water disinfection
TTHM	7/1/2009 - 6/30/2010	34.78438	19 - 52.68	ppb	80	0	By-product of drinking water chlorination

+++++Environmental Protection Agency Required Health Effects Language+++++

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Additional Required Health Effects Language:

Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.

Additional Required Health Effects Violation Notices:

Total organic carbon (TOC) has no health effects. However, TOC provides a medium for the formation of disinfection byproducts (DBPs). These byproducts include trihalomethanes (THMs) and haloacetic acids (HAAs). Drinking water containing these byproducts in excess of the MCL may lead to adverse health effects, liver or kidney problems, or nervous system effects, and may lead to an increase risk of getting cancer.

+++++
 Thank you for allowing us to continue providing your family with clean, quality water this year.

Regulated Contaminates	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
TURBIDITY	3/2010	0.37	0.07-0.37	NTU	0.3		Soil Runoff

Regulated Contaminates	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
TURBIDITY	9-2010	99.45	99.45-100	NTU	0.3		Soil Runoff

NOTE: Turbidity is a measure of the cloudiness of the water. We monitor it because it is a good indicator of the effectiveness of our filtration system. The major source of turbidity includes soil runoff.

Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.

In o
imp
Plea

We
eve
whi